

Annexure-C


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. AE-JSV-Amb-SDC-Lab File-2025-26-

Dated

It is certified that an inspection team headed by **Er. Arun Kumar, Junior Engineer** from **Jal Shakti Vibhag PHED** inspected the **PM SHRI Govt. Model Senior Secondary School Amb, Distt. Una HP** on **27.09.2025** and on the basis of Water Test Report (**Attached**) bearing No. JSV-WTL-Amb-2025-26-386 dated 29.09.2025 of Jal Shakti Divisional Laboratory at Amb (PHED Lab) certified that the **PM SHRI Govt. Model Senior Secondary School Amb, Distt. Una HP** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Government.

This certificate is valid till: - **29.09.2025**.


Assistant Engineer,
Jal Shakti Sub Division Amb
Distt. Una HP 177203
✉ aejsvamb812@gmail.com

To

✓ **The Principal,**
PM SHRI Govt. Model Senior
Secondary School Amb,
Distt. Una HP 177203

HIMACHAL PRADESH
SUB DIVISIONAL WATER TESTING LABORATORY
JAL SHAKTI DIVISION, AMB

TEST REPORT

Test Report No:-JSVWTL-AMB-2025-26:- 386				Date:- 29.09.2025	
Name & Address of Customer: Principal, PM Shri Govt. Senior Secondary School Amb, Distt Una (H.P.)					
Sampling Method:	N/A		Condition of Sample When Received:	OK	
Sample Description:	Water		Name of Source/Scheme:	WSS Amb	
Sample Quantity:	2 Ltr		Name of Panchayat:	NAC Amb	
Collected On:	27.09.2025		Name of Habitation:	Tap in G.S.S.School Amb Premises	
Test Start Date:	27.09.2025		Name of Village:	Amb	
Test End Date:	29.09.2025		Type of Source:	T/Well	

S.No.	Test	Test Method	Result	Requirements As per IS 10500:2012	
				Acceptable Limit	Permissible Limit in the absence of Alternate Source

Physical Parameters

1	Turbidity, NTU, Max.	IS 3025 (PART - 10): 2023	2.0	1 NTU	5 NTU
2	Colour, Hazen Unit, Max.	IS 3025 (PART - 4): 2021	BDL(DL-5)	5	15
3	Odour	IS 3025 (PART - 5): 2018	Agreeable	Agreeable	Agreeable
4	Taste	IS 3025 (PART - 7 & 8): 2022 & 2023	Agreeable	Agreeable	Agreeable
5	pH @ 25° C	IS 3025 (PART - 11): 2022	7.84	6.5 - 8.5	No Relaxation
6	Total Dissolved Solids (Dried @180° C), mg/l, Max.	IS 3025 (PART - 16): 2023	310	500 mg/l	2000 mg/l

Chemical Parameters

7	Total Alkalinity (as CaCO ₃), mg/l, Max.	IS 3025 (PART - 23): 2023	228	200 mg/l	600 mg/l
8	Chloride (as Cl), mg/l, Max.	IS 3025 (PART - 32): 2019	19.85	250 mg/l	1000 mg/l
9	Total Hardness (as CaCO ₃), mg/l, Max.	IS 3025 (PART - 21): 2023	216	200 mg/l	600 mg/l
10	Calcium (as Ca), mg/l, Max.	IS 3025 (PART - 40): 2024	54.50	75 mg/l	200 mg/l
11	Magnesium (as Mg), mg/l, Max.	IS 3025 (PART - 46): 2023	19.44	30 mg/l	100 mg/l

Remarks (if any) **BDL** = Below Detection Limit ; **DL** = Detection Limit ; **NP** = Not Performed

Note:

This report should not be produced partly or full without approval of signatory authority.

The results refer only to tested samples and parameters tested.


Samples will be stored for a period of 5 days from the date of issue of report

Prepared By


Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb


Authorized Signatory

Rajesh Sharma
Assistant Chemist
Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb


Assistant Engineer
Jal Shakti Sub-Division
Amb Distt Una (HP)-177203

HIMACHAL PRADESH
SUB DIVISIONAL WATER TESTING LABORATORY
JAL SHAKTI DIVISION, AMB

TEST REPORT

Test Report No:-JSVWTL-AMB-2025-26:- 386				Date:- 29.09.2025	
Name & Address of Customer: Principal, PM Shri Govt. Senior Secondary School Amb, Distt Una (H.P.)					
Sampling Method:	N/A		Condition of Sample When Received:		OK
Sample Description:	Water		Name of Source/Scheme:		WSS Amb
Sample Quantity:	250 ml		Name of Panchayat:		NAC Amb
Collected On:	27.09.2025		Name of Habitation:		Tap in G.S.S.School Amb Premises
Test Start Date:	27.09.2025		Name of Village:		Amb
Test End Date:	29.09.2025		Type of Source:		T/Well

S.No.	Test	Result	Requirements As per IS 10500:2012	
			Acceptable Limit	Permissible Limit in the absence of Alternate Source

Physical Parameters

1	Temperature (° C)	25.6° C	----	----
---	-------------------	---------	------	------

Chemical Parameters

2	Nitrate (as NO ₃), mg/l, Max.	-	45 mg/l Max	No Relaxation
3	Flouride(as F), mg/l, Max.	-	1.0 mg/l Max	1.5 mg/l Max
4	Sulphate (as SO ₄), mg/l, Max.	-	200 mg/l Max	400 mg/l Max
5	Ammonia (as Total Ammonia-N), mg/l, Max.	-	0.5 mg/l Max	No Relaxation
6	Iron (as Fe), mg/l, Max.	-	1.0 mg/l Max	No Relaxation
7	Manganese(as Mn), mg/l, Max.	-	0.1 mg/l Max	0.3 mg/l Max
8	Total Arsenic (as As), mg/l, Max.	-	0.01 mg/l Max	No Relaxation
9	Free Residual Chlorine, mg/l, Min.	0.2	0.2 mg/l Min	1.0 mg/l Min

Bacteriological Parameters

10	Total Coliform Bacteria (Shall not be detectable in any 100 ml sample)	Nil	Nil	Nil
11	E.Coli (Shall not be detectable in any 100 ml sample)	NP	Nil	Nil

Remarks (if any) **BDL** = Below Detection Limit ; **DL** = Detection Limit ; **NP** = Not Performed

Prepared By


Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb


Authorized Signatory
Rajesh Sharma
Assistant Chemist
Sub Divisional Water Testing Laboratory
Jal Shakti Division, Amb


Assistant Engineer
Jal Shakti Sub-Division
Amb Distt Una (HP)-177203